

07 90 00 Joint Protection

Revision 09/23/2015

Purpose:

The Architect and/or Engineer shall incorporate the Rice specific requirements indicated in this standard's section into their design. The Architect and/or Engineer shall further produce project specifications in line with industry standards that are updated to reflect these Rice specific requirements.

1. General requirements

- a. Expansion joints shall be copper or stainless steel. No galvanized
- b. Use close cell backer rod
- c. Dow Silicone 790 or 795 color to match (non-paintable)
 - i. Exceptions:
 1. Masonry wall: use paintable urethane
 2. Tilt wall construction: use Willseal and caulk